



Ref. No: CS/PQD/016

COMMENTS SHEET

Date: 02.07.2017

PROJECT:	PROPOSED SHOWROOM, OFFICES AND WAREHOUSES AT ROAD 105, INDUSTRIAL AREA
CLIENT:	MANNAI
CONTRACTOR:	AMANA
ATTACHED WITH:	PQD for EXOVA
DOCUMENT/ SUBMITTAL REF NO.:	AMA-J124-SOD-PRQ-CI-039 (REV-01)

DETAILED DESCRIPTION

QDC Comments on the document AMA-J124-SOD-PRQ-CI-039 (REV-01) is as follows;

COMMENTS:

The third-party Inspection M/s. EXOVA have submitted the documents as per QDC comments of their earlier submittal Rev-0 on this subject.



- The documents are found satisfactory.
- Hence the agency is approved as third-party inspection for testing of cementitious fire proof coating application.

The agency will have to submit the following immediately before conducting the test.

Method statement for:

- a) Pull out Test Procedure
- b) Thickness Test System
- c) Dry density test method

STATUS: Approved with Comments

	Signature: 	Approved By:	Signature: 
	Name: SUBAN MURTHY		Name: J. CHANDRA
	Designation: R.E / Sr. Civil Engineer		Designation: Sr. Project Manager